

# FIRE FREE ENGINEER'S

FIRE PROTECTION ENGINEERS & GOVT. CONTRACTORS

Authorised Distributor :-

JAINEX (FIRE & SAFETY) SYSTEM PVT. LIMITED MUMBAI



FIREWELL 2253649

Beside Maharashtra Bhawan,  
Choubey Colony,  
RAIPUR - 493001 (C.G.)  
Mobile : 94252 - 11527

## TEST CERTIFICATE/INSPECTION CERTIFICATE

Customer's Name & Address


Gyan Ganga Educational  
Academy Vidhansabha  
Balade Bazar Road  
Raipur (C.G.)

Date 11/06/25

Next Refill P. 10/06/26

This is to Certify that Mr. R. S. Sahu has made the  
periodical inspection/Testing of the fire Extinguishers installed here.

- Present installation of Fire Extinguishers 04 NOS 01 Kg Capacity ABC Type Fire Extinguishers + 06 NOS 04 Kg Capacity ABC Type + 01 NOS 2 Kg Capacity ABC Type Fire Extinguishers + 02 NOS 06 Kg Capacity ABC Type Fire Extinguishers Complete
- No. of Refills in hand and condition N/A
- Fire Extinguishers for Hydraulic test All fire extinguishers operated Tested and Refilled Found OK
- Extinguishers failed during Hydraulic test N/A
- Any new Fire Extinguishers/Refills required N/A
- State person (s) present at the time of inspection / Testing (1) Jeewan Sahu (2) Raj Kumar (3) Mohan Verma (4) Sanjay Yadav (5) Vijay Tripathi (6) Janak Verma
- Have the Fire Extinguishers being used at any outbreak of fire since last inspection Note :- Fire Extinguishers Dummy Demonstrated



For :- FIRE FREE ENGINEER'S

Jeewan  
Customer's Signature

[Signature]  
Admin Officer

# **FIRE FREE ENGINEERS**

BESIDES MAHARASTRA BHAWAN  
CHOUHEY COLONY, RAIPUR (CG)  
TELE - 07712253649 M-9425525735  
firefree@rediffmail.com

To, Gyanganga Educational Academy  
Vidhansabha Baloda Bazar Road  
Raipur (CG)

## **JOB COMPLETION CERTIFICATE**

Sir,

This is to certify that our representative Shri R. S. Sahu  
has visited your premises & serviced/

refilled/supplied/installed/demonstrated the following equipments:

- (1) ABC Type Fire Extinguishers 04 NOS 01 kg capacity  
ABC type fire
- (2) DCP Type Fire Extinguishers 01 NOS 2 kg capacity  
ABC type fire
- (3) Water-CO2 Fire Extinguishers 06 NOS 04 kg capacity  
ABC type fire
- (4) CO2 Gas Fire Extinguishers 02 NOS 06 kg capacity  
ABC type fire
- (5) Foam Type Fire Extinguishers 02 NOS 06 kg capacity  
ABC type fire

Inspection Dt- 11/06/25

Next Due Dt- 10/06/26

[Signature]  
Customer's Signature  
Name. with official seal and Mobile -

[Signature]  
FFE Representative./Manager  
